



REQUIRED LABELING FOR PHOTOVOLTAIC SYSTEMS

BUILDING SERVICES



Labeling shall comply with CEC Sections 690-5c, 690-10c, 690-17

Labels shall be printed or manufactured so as to be permanent and shall not discolor or be subject to deterioration from exterior / weather conditions. Hand written marker pen labeling will not be allowed.

WARNING

SINGLE 120 VOLT SUPPLY
DO NOT CONNECT MULTI-WIRE
BRANCH CIRCUITS

DISCONNECT

Photovoltaic system from utility

SINGLE SOURCE SYSTEMS
ONLY TO BE PLACED ON THE
PHOTOVOLTAIC SYSTEM
DISCONNECT TO THE MAIN
ELECTRICAL SERVICE

-WARNING- MULTIPLE POWER SOURCES

A PHOTOVOLTAIC SYSTEM
IS PRESENT.
120 VAC and / or 240VAC
may be produced.
DC power circuits
are present on this site.
Batteries may be present on this site.
Disconnect all power sources
before servicing.
Test all voltages
to confirm disconnection.

-WARNING- ELECTRIC SHOCK HAZARD

- Do not touch terminals -
Terminals on BOTH the line and
load sides may be energized
in the open position.

TO BE PLACED ON THE
DISCONNECT FROM THE
SOLAR PANELS TO THE
PHOTOVOLTAIC SYSTEM

TO BE PLACED ON MAIN ELECTRICAL
PANEL COVER