



APPROVED POOL ALARM FEATURES

BUILDING SERVICES



1. Must activate with each opening of door.
2. Allowed to have a means to temporarily de-activate for each separate opening.
3. Must automatically reset after each closing of door.
4. De-activation button shall be mounted a minimum of 60 inches above floor.
5. Shall not have a means to turn unit off.
6. Must be at least 85 db at a distance of 10 feet from door (interior).
7. Must be mounted on interior side of door.

* The following features may be installed in lieu of the pool alarms; an approved mesh pool fencing that meets ASTM Specifications F 2286; Alarms that, when placed in or adjacent to pools, will sound upon detection of accidental or unauthorized entrance into the water meeting the ASTM Specifications F 2208; Other means of protection, if the degree of protection afforded is equal or greater than that afforded by the devices listed above.